

# CLASSICAL

The decomposition effluents at 400 °C (VKT according to DIN 53 436) from the material

Aluminium anodised galvanised 6 – 1,0mm, powder-coated, smooth or perforated with black fibrous

of **durulum GmbH**  
An der Wiese 5  
D-79650 Schopfheim

documented with test report-no: 0019/2022, corresponding to the valid test conditions are considered – with regard to the acute inhalation toxicity – to be **non-hazardous.**

The certificate is valid until 19.08.2024.

These products may be marked with the sign

im Brandfalle rauchgastoxikologisch



unbedenklich

PB-Nr. 0019/2022

Energie- und Prozesstechnik Aachen GmbH

Marktstraße 7

42653 Solingen

[www.epa-aachen.de](http://www.epa-aachen.de)

Issued on 20.08.2022

Dr.-Ing. H.J. Röttger  
(Director Test Centre & Accredited Expert for PA III at DIBt Berlin)