

# DECLARATION

The decomposition effluents at 400 °C (VKT according to DIN 53 436) from the material

Steel anodised galvanised 0,5 – 1,0mm, powder-coated, smooth or perforated with black fibrous

of  
durlum GmbH  
An der Wiese 5  
D-79650 Schopfheim

documented with test report-no. 0015/2022, corresponding to the valid test conditions are considered – with regard to the acute inhalation toxicity – to be **non-hazardous.**

The certificate is valid until 19.08.2024.

These products may be marked with the sign

Im Brandfalle  
rauchgastoxikologisch

**ARCH**

unbedenklich

PB-Nr. 0015/2022

Energie- und Prozesstechnik Aachen GmbH

Marktstraße 7

42653 Solingen

[www.epa-aachen.de](http://www.epa-aachen.de)

Issued on 20.08.2022

  
Dr.-Ing. H.J. Röttger  
(Director Test Centre & Accredited Expert for PA-III at DIBt Berlin)